




Luminaire Schedule							
Project: Project_1							
Symbol	Qty	Tag	Arrangement	Luminaire Watts	Luminaire Lumens	LLF	Description
	28		Single	15.0178	1873	0.900	WDGE1 LED P2 40K 80CRI VF
	7	R3H	Single	114.07	10988	0.900	RSX2 LED P2 40K R3 HS(SINGEL LED PARKING LIGHT WITH HOUSE-SHIELD , 25FT STEEL POLE WITH 30IN CONCRETE BASE)
	10	R4H	Single	114.07	10424	0.900	RSX2 LED P2 40K R4 HS (SINGEL LED PARKING LIGHT WITH HOUSE-SHIELD , 25FT STEEL POLE WITH 30IN CONCRETE BASE)
	13	R5	Single	149.98	20308	0.900	RSX2 LED P3 40K R5 (TWIN LED PARKING LIGHT FIXTURE, 25FT STEEL POLE WITH 30IN CONCRETE BASE)

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
E NEW PARKING LOT 302_E NEW PARKIN	Illuminance	Fc	1.77	3.4	0.5	3.54	6.80
N NEW PARKING LOT 302_N NEW PARKIN	Illuminance	Fc	1.15	1.9	0.7	1.64	2.71
NEW PARKING LOT 301_NEW PARKING	Illuminance	Fc	1.47	3.4	0.5	2.94	6.80
PERIMATER	Illuminance	Fc	0.62	5.7	0.0	N.A.	N.A.
SW NEW PARKING LOT_Planar	Illuminance	Fc	1.62	2.6	0.4	4.05	6.50
W NEW PARKING LOT 302_W NEW PARKIN	Illuminance	Fc	1.72	5.3	0.3	5.73	17.67

PROJECT NUMBER: 24007

DISCLAIMER:
-Illuminating Engineering Society recommended illuminance targets are used where applicable.
-THE FIXTURE TYPES, LUMEN PACKAGES AND/OR LAMPINGS, COLOR TEMPERATURES, CRI, LIGHT-LOSS FACTORS, AND REFLECTANCE VALUES SPECIFIED ON THIS LAYOUT MUST BE USED IN ORDER TO MEET THE EXACT CRITERIA AND PERFORMANCE DATA SHOWN.

9229 Delegates Row Suite 150
Indianapolis, IN 46240-3825
PH: 317.781.6200
www.circledesigngroup.com



JOHNSON COUNTY COURT
SITE PLAN

Filename: 24007 Site plan lighting photometrics (2).AGI

Date:8/13/2024